

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 978 861
Permit No.
Basin 109

NOTICE OF INTENT NO 51545
4040 Drake Way

1. OWNER Jeffrey Forbes
MAILING ADDRESS 4040 Drake Way
Reno NV

ADDRESS AT WELL LOCATION

2. Location NE 1/4 SW 1/4 Sec 32 T 16N R 20E
PERMIT NO. PARCEL NO. 050-395-18

Washoe County

SUBDIVISION NAME

| | | | | | | | | |
|--|---------|-------------|--|------------|-------|--------------|--|---|
| 3. WORK PERFORMED | | | 4. PROPOSED USE | | | 5. WELL TYPE | | |
| New Well | Replace | Recondition | <input checked="" type="checkbox"/> Domestic | Irrigation | Test | Cable | <input checked="" type="checkbox"/> Rotary | RVC |
| <input checked="" type="checkbox"/> Deepen | Abandon | Other | Municipal/Industrial | Monitor | Stock | Air | Other | <input checked="" type="checkbox"/> Mud |

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|----------|--------------|------|-----|-----------|
| Sand. | | 180 | 243 | 63 |
| Granite | | 243 | 290 | 47 |

8. WELL CONSTRUCTION

Depth Drilled 290 feet Depth Cased 290 feet
HOLE DIAMETER (BIT SIZE)

| | From | To | |
|--------------|----------|----------|--|
| 6 1/8 inches | 180 feet | 290 feet | |
| inches | feet | feet | |
| inches | feet | feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 5 | 6.96 | 188 | 150 | 290 |

Perforations:

| Type Perforation | Factory |
|------------------|-------------|
| Size perforation | 3/32 x 3" |
| From 190 feet | to 210 feet |
| From 270 feet | to 290 feet |
| From | to |
| From | to |
| From | to |

Surface Seal YES No
Depth of Seal feet Seal Type:
Pumped Cement Grout
Poured Concrete Grout

Gravel Packed: Yes No
From 0 feet to feet

RECEIVED
03 OCT 15 AM 11:55
STATE ENGINEERS OFFICE

Date started 9-15 -03
Date completed 9-20 -03

7. WELL TEST DATA

| TEST METHOD: | Bailer | Pump | x | Air Lift |
|--------------|-------------------------------|------|---|--------------|
| G.P.M. | Draw Down (Feet Below Static) | | | Time (hours) |
| 8 | 145 | | | |

9. WATER LEVEL

Static water level 140 feet below land surface
Artesian flow 0 GPM 0 P.S.I.
Water Temperature cold Degrees F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name McKay Drilling, Inc.
2290 Pioneer Drive
Reno, NV 89509

NV Contractors No. 14170
NV Driller's Lic (on site) 2121

Signed *Steve McKay*
By driller performing actual drilling on site or contractor

Date 9-23 -03