WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90873
Permit No.
Basin 158

NOTICE OF INTENT NO. 25156

1. OWNER Elizabeth Hall
MAILING ADDRESS 8 Farrell Ln Yerington NV 89447
ADDRESS AT WELL LOCATION 2A Farrell Lane Yerington NV 89447

2. LOCATION SE ¼ SE ¼ Sec. 4 T. 14 N/S R. 25 E. Lyon County
PERMIT NO. — Issued by Water Resources
14-211-04 Parcel No.
PM 86423 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Brown Clay		2	12	10
Coarse Sand + Small Gravel		12	18	6
Brown Clay		18	22	4
Blue Clay + Fine Sand		22	27	5
Coarse Sand		27	38	11
Brown Clay + Fine Sand		38	50	12
Fine To Coarse Sand + Blue Clay Strata		50	58	8
Coarse Sand + Small Gravel + Brown Clay		58	66	8
Brown clay + Small Gravel		66	77	11
Brown Clay		77	85	8
Brown clay + Coarse Sand		85	90	5
Fine To Coarse Sand		90	95	5
Coarse Sand + Small Gravel	X	95	110	15
Coarse Sand + Small Gravel + Clay	X	110	114	4

Date started 12-13-96, 19
Date completed 12-20-96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Lift	20	30' air line	30 mins.
Air Lift	60	60' air line	2 HRS

8. WELL CONSTRUCTION
Depth Drilled 114 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	114 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.42	.188	+1	114

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 104 feet to 114 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 114 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Ln (Contractor)
Yerington
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Larry Ogden (By driller performing actual drilling on site or contractor)
Date 12-27-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627