WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90874
Permit No.
Basin 107

NOTICE OF INTENT NO. 47923

1. OWNER MIKE & NANCY MASSIN
MAILING ADDRESS PO. BOX 149, WELLINGTON, NV 89444
ADDRESS AT WELL LOCATION 32 PINON DR. WELLINGTON, NV. 89444

2. LOCATION NE ¼ SW ¼ Sec. 10 T. 11 N/S R. 23 E. LYON County
PERMIT NO. (Issued by Water Resources) 009-051-05 (Parcel No.) VALLEY VIEW RANCHOS (Subdivision Name)

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE: [X] Cable [ ] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL / ALLUVIAL D.G.	N	0	6	6
ALLUVIAL D.G.	N	6	53	
ROCK / D.G.	N	53	56	3
D.G.	N	56	68	
HARD GRANITE ROCK	N	68	71	
BROWN. CLAY / D.G.	N	71	93	
COARSE SAND	N	93	112	
BROWN. CLAY / D.G.	N	112	160	
COARSE SAND	Y	160	172	
COARSE SAND / PEA GRAV.	Y	172	180	
PEA GRAVEL.	Y	180	222	
BLUE CLAY / PEA GR.	N	222	227	

Date started AUG 28 03, 19
Date completed SEPT. 16 03, 19

7. WELL TEST DATA

TEST METHOD: [X] Bailer [X] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
BAIL	14	5	4
PUMP	18	5	6

8. WELL CONSTRUCTION
Depth Drilled 227 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	60	Feet
6 5/8	Inches	60	Feet	225	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	+1.5	225

Perforations:
Type perforation FACTORY SAW SLOT
Size perforation .060 X 3" X 8" OC X 6 ROWS
From 185 feet to 225 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 145 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDMUND MILLER DRILLING (Contractor)
Address PO BOX 218 ~~WELLINGTON~~ SMITH (Contractor)
NV. 89430
Nevada contractor's license number issued by the State Contractor's Board 32166-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date SEPT. 24, 03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627