WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90882
Permit No.
Basin 088

NOTICE OF INTENT NO. 48785

1. OWNER Jenny Johnson
MAILING ADDRESS 15340 Callahan Ranch Rd.
Reno, NV 89511

ADDRESS AT WELL LOCATION 15340 Callahan Ranch Rd.

2. LOCATION NW 1/4 NE 1/4 Sec. 2 T 17N N/S R 19E E Washoe County
PERMIT NO. (Issued by Water Resources) 045-552-16 (Parcel No.) Subdivision Name

3. **WORK PERFORMED**
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. **PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other mud

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Top soil & D.G.		0	15	15
Coarse sand boulders & pea gravel		15	55	40
Gravel coarse sand boulders	x	55	215	160
Boulders coarse sand	x	215	302	87
Washoe county well permit WL030222				

RECEIVED
03 OCT 23 AM 11:36
STATE ENGINEERS OFFICE

Date started 10/9/2003, 19__
Date completed 10/10/2003, 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		3

8. **WELL CONSTRUCTION**
Depth Drilled 302 Feet Depth Cased 302 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	302	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	302

Perforations:
Type perforation Machine Cut
Size perforation 3/32 x 3
From 262 feet to 302 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 302 feet

9. **WATER LEVEL**
Static water level 116 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 10/14/03

USE ADDITIONAL SHEETS IF NECESSARY