

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48679

1. OWNER Mike Marigold ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO Box 18648 75 Ox Yoke Ln
Reno, NV 89511 Reno, NV
 2. LOCATION NW 1/4 NE 1/4 Sec 4 T 17 S R 20 E Washoe County
 PERMIT NO. WL 030145 017-310-24 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Cobbles silt Brown Clay</u>		<u>0</u>	<u>45</u>	<u>45</u>
<u>Volcanic Sands</u>		<u>45</u>	<u>55</u>	<u>10</u>
<u>Cobbles silt Brown Clay</u>		<u>55</u>	<u>85</u>	<u>30</u>
<u>Broken Volcanic Rock</u>				
<u>Brown Clay</u>		<u>85</u>	<u>140</u>	<u>55</u>
<u>Broken Volcanic Rock with small amounts of Brown Clay and silt</u>		<u>140</u>	<u>180</u>	<u>40</u>

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.158</u>	<u>72</u>	<u>140</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3/32
 From 140 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 100'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 180 feet to 100 feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

Date started 8/28/03, 20____
 Date completed 8/29/03, 20____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Air Lift for 30</u>			<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA PUMP & DRILLING Contractor
 Address P.O. BOX 2227 Contractor
DAYTON, NV 89403
 Nevada contractor's license number issued by the State Contractor's Board 46357
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed W.D.M.
 By driller performing actual drilling on site or contractor
 Date 9-15-03