

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48678

1. OWNER Jim Paddock ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1544 Pittman Ave _____
Sparks, NV 89431 _____
 2. LOCATION NW 1/4 NE 1/4 Sec 4 T 17 R 20 E _____
Washoe County
 PERMIT NO. WL 030143 | 017-310-23 _____
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Cobbles silt</u>		<u>0</u>	<u>30</u>	<u>30</u>
<u>Volcanic Sands</u>		<u>30</u>	<u>45</u>	<u>15</u>
<u>Cobbles silt Brown clay</u>		<u>45</u>	<u>75</u>	<u>30</u>
<u>Fractured Block + Brown volcanics</u>	<u>✓</u>	<u>75</u>	<u>180</u>	

8. WELL CONSTRUCTION
 Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)
 From 10 3/8 Inches To 0 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.158</u>	<u>70</u>	<u>140</u>

Perforations:
 Type perforation Mill slot
 Size perforation 3/32

From 140 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 100 _____ Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 180 feet to 100 feet

9. WATER LEVEL
 Static water level 10' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA PUMP & DRILLING Contractor
 Address P.O. BOX 2227 Contractor
DAYTON, NV 89403

Nevada contractor's license number issued by the State Contractor's Board 46357
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790

Signed Marty Lopez
 By driller performing actual drilling on site or contractor
 Date 9-15-03

Date started 8/22/03, 20____
 Date completed 8/28/03, 20____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air Lift</u>	<u>70-50</u>		<u>24 hours</u>