WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90895
Permit No.
Basin 087

NOTICE OF INTENT NO. 49205

1. OWNER McGinley + Associates
MAILING ADDRESS 5690 Riggins Court Ste C Reno N.V 89502
ADDRESS AT WELL LOCATION 755 International Way Sparks N.V

2. LOCATION SW ¼ NE ¼ Sec. 3 T. 19 N/S R. 20 E/W Washoe County
PERMIT NO. Issued by Water Resources
032-302-21 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| I removed the Flush | | | | |
| mount. Then I checked | | | | |
| for water. Then I | | | | |
| drilled out the casing | | | | |
| after that I pumped | | | | |
| with tremie pipe | | | | |
| from the bottom to | | | | |
| the surface cement | | | | |
| grout. After doing | | | | |
| that pulled the | | | | |
| pipe to look the | | | | |
| surrounding area | | | | |
| with cellpack. | | | | |

Date started 9-24, 2003
Date completed 9-24, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| None | | |

8. WELL CONSTRUCTION
Depth Drilled 27' Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 8" Inches | 0' Feet | 27' Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4" | Sch 40 | 1/4 inch | | |
| | | | | |
| | | | | |

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0' to 27'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 27.9 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 55 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling Inc. Contractor
Address P.O. Box 940 Meridian Contractor
ID 83680
Nevada contractor's license number issued by the State Contractor's Board CC33818
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2256
Signed Jason Adams
By driller performing actual drilling on site or contractor
Date 10-14-03

(Rev. 12-01)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627