WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90896
Permit No.
Basin 087

NOTICE OF INTENT NO. 49205

1. OWNER McGinley + Associates
MAILING ADDRESS 5690 Riggins Court, Ste C. Reno NV 89502
ADDRESS AT WELL LOCATION 755 International Way Sparks, NV

2. LOCATION SW ¼ NE ¼ Sec. 3 T 19 (N)/S R 20 (E) 89502 Washoe County
PERMIT NO. (Issued by Water Resources) 032-302-21 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
I removed the Flush mount, then I measured the water level at 24 ft. After that I pulled the casing out then pumped Cement Grout by trimmie pipe from bottom to surface. Then I matched the surrounding area by patching the hole with Cold patch				

Date started 9-24, 20 03
Date completed 9-24, 20 03

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NONE		

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0' Feet	30' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch 40	1/4 inch		

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0' to 30'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 24.9 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 55 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling Inc. (Contractor)
Address P.O. Box 3 Mendon UT 84325 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board C0358018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2256
Signed (By driller performing actual drilling on site or contractor)
Date 10-14-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627