

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 90901
 Permit No. _____
 Basin 107
 NOTICE OF INTENT NO. 99012

1. OWNER JIM FULSTROM ADDRESS AT WELL LOCATION Lower Colony Rd. Wellington, NV
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 SE 27 T 11 N/S R. 23 E LYON CO County
 PERMIT NO. 10-291-39 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silt, Sand Gravel		0	63'	63'
Clay & Sand Layers	✓	63'	220'	
Clay	✓	220'	240'	
Course Sand & Silt	✓	240'	331'	
Coarse & O.G. Fractured	✓	331'	342'	

8. WELL CONSTRUCTION
 Depth Drilled 342 Feet Depth Cased 342 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 3/4 Inches To 0 Feet 342 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>.188</u>	<u>+1</u>	<u>342'</u>

Perforations:
 Type perforation Sawed
 Size perforation 18x3" 6# Rows
 From _____ feet to _____ feet
 From 142' feet to 342' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 342' feet

9. WATER LEVEL
 Static water level 52' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Clear

Date started Aug 4 '03 19____
 Date completed Aug 12 '03 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	<u>200+ Plus</u>		<u>3 Hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leach Drilling Inc Contractor
 Address PO Box 599 Contractor
Silver Springs W. 89429
 Nevada contractor's license number 31841 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
 Signed Matthew D. Leach
 By driller performing actual drilling on site or contractor
 Date Sept 12 '03

RECEIVED
 AUG 10 11:05 AM
 DIVISION OF WATER RESOURCES OFFICE