

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 9090
 Permit No. 62829T
 Basin 061
 NOTICE OF INTENT NO. 52553

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **Barrick Goldstrike Mines** VD97-10 ADDRESS AT WELL LOCATION **Barrick Goldstrike minesite, north of Carlin, NV.**
 MAILING ADDRESS **P.O. Box 29**
Elko, NV 89803

2. LOCATION **SE SE 1/4 NE 1/4 Sec. 19 T 36N** N/S R **50** E **Eureka** County
 PERMIT NO. **62829-T 63127** N/A Parcel No. **N/A** Subdivision Name **N/A**
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned by pumping abantonite, via tremie from T.D. to 440', where it would rise no further, poured hole plug while pumping abantonite to 20', and capped with neat cement.				
Quantities Used:				
Cement: 4 cu.ft.				
Hole plug: 60 cu.ft.				
Abantonite: 88 cu.ft.				

RECEIVED
 OCT 27 PM 12:07
 STATE ENGINEERS OFFICE

Date started 10/9/2003, 19
 Date completed 10/9/2003, 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	

8. WELL CONSTRUCTION

Depth Drilled 750 Feet Depth Cased 750 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
<u>16</u>	<u>0</u>		<u>40</u>	
<u>9.25</u>	<u>40</u>		<u>750</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12.750</u>	<u>33.38</u>	<u>0.250</u>	<u>0</u>	<u>40</u>
<u>6.625</u>	<u>17.02</u>	<u>0.250</u>	<u>0</u>	<u>750</u>

Perforations:
 Type perforation Slot
 Size perforation 2" X 0.125"

From	feet to	feet
<u>110</u>		<u>750</u>

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100'

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 100 feet to 750 feet

9. WATER LEVEL

Static water level 451 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2144

Signed Paul Stoddard
 By driller performing actual drilling on-site or contractor

Date 10/23/03

B.S.T.C