


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 90905
 Permit No. 55143
 Basin 061



NOTICE OF INTENT NO. 52559

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Barrick Goldstrike Mines BW-15 ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803

2. LOCATION NW 1/4 SW 1/4 Sec. 24 T 36N N/S R 49 E Eureka County
 PERMIT NO. 55143 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned by pumping abantonite via tremie from T.D. to 1770', where it would rise no further. Then poured hole plug while pumping abantonite to 760'. Placed a cement bridge plug from 760' to 740'. Poured clean fill to 20', and capped with neat cement.				
Quantities Used:				
Cement: 44 cu.ft.				
Fill: 1570 cu.ft.				
Cement: 35.4 cu.ft.				
Hole plug: 1170 cu.ft.				
Abantonite: 3152 cu.ft.				

8. WELL CONSTRUCTION

Depth Drilled 2080 Feet Depth Cased 2080 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>39</u>	<u>0</u>	<u>22</u>	<u>Feet</u>
<u>30</u>	<u>22</u>	<u>1630</u>	<u>Feet</u>
<u>19</u>	<u>1630</u>	<u>2080</u>	<u>Feet</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>32</u>	<u>126.70</u>	<u>0.375</u>	<u>0</u>	<u>22</u>
<u>20</u>	<u>78.60</u>	<u>0.375</u>	<u>22</u>	<u>1623</u>
<u>16</u>	<u>62.58</u>	<u>0.375</u>	<u>1460</u>	<u>2080</u>

Perforations:
 Type perforation Louver
 Size perforation 0.125"

From	To	Feet
<u>820</u>	<u>2080</u>	<u>feet to feet</u>
		<u>feet to feet</u>

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50' Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 1620 feet

Date started 10/19/2003, 19
 Date completed 10/20/2003, 19

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL

Static water level 1810 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2084

Signed Vince Glasdie
 By driller performing actual drilling on-site or contractor
 Date 10/23/03

BSTL