


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 90906
 Permit No. 55141
 Basin 661



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52555

1. OWNER Barrick Goldstrike Mines EW-13 ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803

2. LOCATION NW 1/4 NE 1/4 Sec. 19 T 36N N/S R 50 E Eureka County
 PERMIT NO. 55141 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned by pumping abantonite via tremie from T.D. to 603', where it would rise no further. Poured hole plug while pumping abantonite to 20', and capped with neat cement.				
Quantities Used:				
Cement: 34 cu.ft.				
Hole plug: 480 cu.ft.				
Abantonite: 329 cu.ft.				

RECEIVED
 19 OCT 27 PM 12:07
 STATE ENGINEERS OFFICE

Date started 10/8/2003 , 19
 Date completed 10/9/2003 , 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	

8. WELL CONSTRUCTION

Depth Drilled 1000 Feet Depth Cased 992 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>36</u>	<u>0</u>	<u>100</u>	<u>Feet</u>
<u>17.5</u>	<u>100</u>	<u>1000</u>	<u>Feet</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>20</u>	<u>78.60</u>	<u>0.375</u>	<u>0</u>	<u>40</u>
<u>12.75</u>	<u>33.38</u>	<u>0.250</u>	<u>0</u>	<u>992</u>

Perforations:
 Type perforation Mill Slot and Louver
 Size perforation 0.250"

From	feet to		feet
<u>152</u>	<u>192 (L)</u>		
<u>232</u>	<u>272 (L)</u>		
<u>312</u>	<u>352 (L)</u>		
<u>392</u>	<u>992 (MS)</u>		

Surface Seal: Yes No Seal Type:
 Neat Cement Cement Grout Concrete Grout
 Depth of Seal 100'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 1000 feet

9. WATER LEVEL
 Static water level 624 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2144
 Signed Paul Stoddard
 By driller performing actual drilling on-site or contractor
 Date 10/23/03

B.S.T.L