


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 90909  
 Permit No. 5514  
 Basin 06



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52554

1. OWNER Barrick Goldstrike Mines VD97-22 ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV  
 MAILING ADDRESS P.O. Box 29  
Elko, NV 89803

2. LOCATION NE 1/4 NW 1/4 Sec. 19 T 36N N/S R 50 E Eureka County  
 PERMIT NO. 55141 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
While running the tremie pipe into the well, it was found that the well was sheared at 200'. The well is in the area where numerous wells have sheared off. Our past experience shows that drilling through these sheared casings results in the bit drilling through the casing and starting a new hole. Thus, we chose not to try this on this well. We pumped abantonite via tremie from the shear to 110'. Poured hole plug while pumping abantonite to 20' and capped with neat cement.				
Quantities Used:				
Cement: 6 cu.ft.				
Hole plug: 30 cu.ft.				
Abantonite: 131cu.ft.				

Date started 10/20/2003 . 19  
 Date completed 10/21/2003 . 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

8. WELL CONSTRUCTION

Depth Drilled 810 Feet Depth Cased 801.9 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>17.750</u>	<u>0</u>	<u>20</u>	Feet
<u>9.875</u>	<u>20</u>	<u>810</u>	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12.750</u>	<u>33.38</u>	<u>0.250</u>	<u>0</u>	<u>20</u>
<u>6.625</u>	<u>17.02</u>	<u>0.250</u>	<u>+2</u>	<u>801.9</u>

Perforations:  
 Type perforation Louwer  
 Size perforation 0.125"

From	To	feet to	feet
<u>120.3</u>	<u>801.9</u>		

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 100 feet to 810 feet

9. WATER LEVEL  
 Static water level Not Measured feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Lang Exploratory Drilling Contractor  
 Address P.O. Box 5279 Contractor  
Elko, NV 89802-5279  
 Nevada contractor's license number issued by the State Contractor's Board 0021976  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2084  
 Signed Vince Hardie  
 By driller performing actual drilling on-site or contractor  
 Date 10/23/03

*B. S. L.*