

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 90910
 Permit No. 55141
 Basin 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52556

1. OWNER Barrick Goldstrike Mines EW-26 ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803

2. LOCATION SW 1/4 NE 1/4 Sec. 19 T 36N N/S R 50 E Eureka County
 PERMIT NO. 55141 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|------|----|------------|
| Abandoned by pumping abantonite via tremie from T.D. to 403', where it would rise no further. Poured hole plug while pumping abantonite to 20', and capped with neat cement. | | | | |
| Quantities Used: | | | | |
| Cement: 21.2 cu.ft. | | | | |
| Hole plug: 360 cu.ft. | | | | |
| Abantonite: 669 cu.ft. | | | | |

RECEIVED
 OCT 27 PM 12:07
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 968 Feet Depth Cased 960 Feet

HOLE DIAMETER (BIT SIZE)

| From | To |
|--------------------|-----------------|
| <u>36</u> Inches | <u>0</u> Feet |
| <u>17.5</u> Inches | <u>38</u> Feet |
| | <u>968</u> Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>24</u> | <u>94.92</u> | <u>0.375</u> | <u>0</u> | <u>38</u> |
| <u>12.75</u> | <u>33.38</u> | <u>0.250</u> | <u>0</u> | <u>960</u> |

Perforations:
 Type perforation Louwer
 Size perforation 0.125"

| From | To |
|--------------------|-----------------|
| <u>120</u> feet to | <u>960</u> feet |
| | |
| | |
| | |
| | |

Surface Seal: Yes No Seal Type:
 Depth of Seal 105' Neat Cement
 Placement Method: Pumped Poured Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 105 feet to 968 feet

9. WATER LEVEL
 Static water level 403 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2144

Signed Paul Stoddard
 By driller performing actual drilling on-site or contractor

Date 10/23/03

Date started 10/7/2003, 19
 Date completed 10/8/2003, 19

7. WELL TEST DATA

| TEST METHOD: | Bailer | Pump | Air Lift |
|--------------|-------------------------------|--------------|----------|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) | |
| | | | |
| | | | |
| | | | |

B.S.L.