

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 90914
 Permit No. 45544
 Basin 061
 NOTICE OF INTENT NO. 52560

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Glamis Gold #3
 MAILING ADDRESS P.O. Box 160
Valmy, NV 89438

ADDRESS AT WELL LOCATION Dee Gold minesite, about
30 miles north of Carlin, NV.

2. LOCATION SE 1/4 SW 1/4 Sec. 3 T 36N N/S R 49 E Elko County
 PERMIT NO. 45544 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Monitor Municipal/Industrial Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned by pumping abantonite via tremie to 395', where it would rise no further, then poured hole plug while pumping abantonite to 20', and capped with neat cement.				
Quantities Used:				
Cement: 35 cu.ft.				
Hole plug: 152 cu.ft.				
Abantonite: 1167 cu.ft.				

RECEIVED
 OCT 27 PM 12:07
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
	0		50	
	50		360	
15	360		500	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
26			+2	50
16			+2	360
12.75	33.38	0.250	+2	500

Perforations:
 Type perforation Wire Wrap and Mill Slot
 Size perforation 0.100" 3" X 0.125"

From	Feet to	Seal Type	Feet
From	200	360 (MS)	feet
From	360	500 (WR)	feet
From			feet
From			feet
From			feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 360'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 500 feet

Date started 10/21/2003, 19
 Date completed 10/22/2003, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level Dry feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2084
 Signed Vince Hardee
 By driller performing actual drilling on-site or contractor
 Date 10/23/03

B-STA