WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90943
Permit No.
Basin 212

NOTICE OF INTENT NO. 24251

1. OWNER SOUTHWEST HOMES
MAILING ADDRESS 7001 N SCOTTDALE RD ENT #10
SCOTTSDALE, AZ 85253-3671

ADDRESS AT WELL LOCATION CACTUS & JONES
LAS VEGAS, NV 6020 SOMERSET HILLS AVE

2. LOCATION NW ¼ NW ¼ Sec. 36 T. 22 N/S R. 60 E. CLARK County
PERMIT NO. (Issued by Water Resources) 176-36-101-004 (Parcel No.) 910 WSE (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Plug 1 domestic well				
North well				
Depth 362'				
Casing 8 3/8"				
Static water level 339'				
Placed 5 yards of W171 slurry up to 280'. Allow to harden and placed 6.5 yards of 1307831 sand and cement grout to surface.				
Perforate from bottom up to 250'.				
PLUGGING OF LOG # 52920				

DCNR/DWR RECEIVED OCT 07 2003 LAS VEGAS OFFICE

Date started 10/1/03, 20
Date completed 10/1/03, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4015 WEST TOMPKINS AVE. (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed Fred B. Allen III
By driller performing actual drilling on site or contractor
Date 10/6/03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627