WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90944
Permit No.
Basin 212

NOTICE OF INTENT NO. 25283 4

1. OWNER SOUTHWEST HOMES
MAILING ADDRESS 3140 S RAINBOW BLVD #400
LAS VEGAS, NV 89119

ADDRESS AT WELL LOCATION 6020 SOMERSET HILLS AVE
LAS VEGAS, NV

2. LOCATION NW 1/4 NW 1/4 Sec. 36 T. 22 N/S R. 60 E. CLARK County
PERMIT NO. (Issued by Water Resources) 176-36-101-010 (Parcel No.) 010 (Subdivision Name) wde

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Plug 1 domestic well				
South well				
Depth 565'				
Casing 8 5/8"				
Static water level 344'				
Camera well and found				
obstruction at 217', found top				
of 6" liner at 217'. Drilled				
out debris to 580'.				
Trimmied 5 yards of W171.				
Perforate from bottom to 280'				
then top off with 4 yards of				
1307831 sand and cement				
grout.				
PLUGGING OF LOG 52920				

DCNR/DWR
RECEIVED
OCT 2003
LAS VEGAS OFFICE

Date started 10/1/03, 20
Date completed 10/1/03, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4015 WEST TOMPKINS AVE. (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed Fred B Allen III
By driller performing actual drilling on site or contractor
Date 10/6/03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627