

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24968

1. OWNER IRON MOUNTAIN RANCH ALLIANCE LLC ADDRESS AT WELL LOCATION 5900 GRAND TETON
 MAILING ADDRESS 2810 W CHARLESTON #81 LAS VEGAS, NV
LAS VEGAS, NV 89102-1910

2. LOCATION SE 1/4 SW 1/4 Sec. 12 T 19 N/S R 60 E CLARK County
 PERMIT NO. R1215 125-12-401-002 GEO TEK
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Plug 1-8" domestic well				
Casing 8 5/8"				
Encountered steel obstruction at 101'				
Drilled steel out down to 114'				
Installed camera and saw that appears to be 3" drop pipe that was mushroomed out by drilling.				
Obtained waiver #R1215 to delete perforating.				
Ran 2" timmie passed 3" production pipe to 397'.				
Place 3 yards of W171 to top of well.				
Water level at 160'				
Perforate 113' to 50'				

DGNR/DWR
RECEIVED
SEP 23 2003
LAS VEGAS OFFICE

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation _____
 Size perforation _____

From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 9/9/03, 20 _____
 Date completed 9/19/03, 20 _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING INC. Contractor
 Address 4015 WEST TOMPKINS AVE. Contractor
LAS VEGAS, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 18917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301

Signed Allen B. Allen
 By driller performing actual drilling on site or contractor
 Date 9/24/03