

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25115

1. OWNER Jie Schilling ADDRESS AT WELL LOCATION N.W. CORNER DEER SPRING & JEANETTE
 MAILING ADDRESS _____

2. LOCATION SE 1/4 NW 1/4 Sec 24 T 19S N/S R 60 E Clark County _____
 PERMIT NO. 125-24-202-012
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Popcorn Caliche		0	15	
Benonite Clay		15	22	
Caliche		22	95	
Reddish Clay		95	160	
Caliche		160	250	
Clay & Gravel & Water	xx	250	275	
Clay		275	460	
Clay & Water	xx	460	475	
Clay		475	530	
Gravel Clay & Water	xx	530	607	

DCNR/DWR
RECEIVED
SEP 11 2003
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 607 Feet Depth Cased 607 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 607 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	607

Perforations:
 Type perforation Torch
 Size perforation 3/16 x 4 row
 From 500 feet to 600 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 240
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 130 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 N. Bonita Vista St. Contractor
Las Vegas, Nev. 89149
 Nevada contractor's license number 10062
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed V H Dimick
 By driller performing actual drilling on site or contractor
 Date 09-18-03

Date started 9/9/03, 19_____
 Date completed 9/17/03, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)