

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 20715
 ADDRESS AT WELL LOCATION 4151 E. Theusa rd. 4.6

1. OWNER John GLYNN ADDRESS AT WELL LOCATION 4151 E. Theusa rd. 4.6
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NW 1/4 Sec. 17 T. 21 N. R. 53 E. NYC County
 PERMIT NO. 045-171-36 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>0-4 Sandy silt</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>4-12 Brown clay</u>		<u>4</u>	<u>12</u>	<u>8</u>
<u>Grey Clay</u>		<u>12</u>	<u>27</u>	<u>15</u>
<u>Caliche</u>		<u>27</u>	<u>32</u>	<u>5</u>
<u>Grey Clay</u>		<u>32</u>	<u>47</u>	<u>15</u>
<u>Brown clay</u>	<u>X</u>	<u>47</u>	<u>62</u>	<u>15</u>
<u>Light Bl. clay</u>	<u>X</u>	<u>62</u>	<u>150</u>	<u>88</u>
<u>Grey Clay</u>	<u>X</u>	<u>150</u>	<u>160</u>	<u>10</u>

DCNR/DWR
 RECEIVED
 OCT 21 2003
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 160
12 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>Scd 40</u>		<u>0</u>	<u>160</u>

Perforations:
 Type perforation Saw
 Size perforation 4x6
 From 110 feet to 160 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Poured Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 61 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 9-19, 2003
 Date completed 9-24, 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>40</u>	<u>1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Larry's Water well service
 Address P.O. Box 3392
Pahrump NV. 89041
 Nevada contractor's license number 0035901
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1916
 Division of Water Resources the on-site driller.
 Signed Larry Jenkins
 By driller performing actual drilling on site or contractor
 Date 9-29-03