WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91025
Permit No.
Basin 212

NOTICE OF INTENT NO. 25781

1. OWNER Julie, Brian Lee / Mary, Anton Scoutwell
MAILING ADDRESS 9960 W. Cheyenne Ave. #210 Las Vegas NV 89129
ADDRESS AT WELL LOCATION Lot North of 5111 Donna

2. LOCATION SW ¼ NW ¼ Sec. 35 T. 19 N/S R. 60 E. County
PERMIT NO. Log-60713 (Issued by Water Resources) | 124-35-304-002 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☒ Other Plug

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
~~pto~~ pulled 105'				
~~pto~~ pump, pipe,				
cable.				
bailed 177 to				
200 ft.				
perforated from.				
200-50 ft.				
pumped 440 of				
neat cement.				
from bottom to surface.				
cut 5' below				
surfaces. & backfilled				

DCNR/DWR
RECEIVED
OCT 24 2003
LAS VEGAS OFFICE

Date started Sept. 2, 2003
Date completed Sept 15, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ..... Feet Depth Cased ..... Feet

HOLE DIAMETER (BIT SIZE)
From To
..... Inches ..... Feet ..... Feet
..... Inches ..... Feet ..... Feet
..... Inches ..... Feet ..... Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 72. feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BLW. Group. (Contractor)
Address 4145 Artic Spring Rd. (Contractor)
Las Vegas Nevada 89115
Nevada contractor's license number issued by the State Contractor's Board 035639
Nevada driller's license number issued by the Division of Water Resources, the on-site driller R&P LTD. 2248
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-23-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627