

OFFICE USE ONLY  
 Log No. 91032  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 25388

1. OWNER Fiesta Homes ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3365 Wynn Rd #G Commerce & Craig  
Las Vegas NV, 89102  
 2. LOCATION 8 E 1/4 N E 1/4 Sec. 03 T. 20 N/S R. 61 E Clark County  
 PERMIT NO. 53959 | 139-03-502-009  
LOG# Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Ripped from</u>		<u>25</u>	<u>80</u>	<u>55'</u>
<u>Pumped 2 yds</u>				
<u>Neat cement from</u>				
<u>Bottom to surface</u>				
<u>No casing in hole</u>				
<u>from 80ft</u>				
<u>to bottom 150</u>				

DGWR/DWR  
 RECEIVED  
 OCT 15 2003  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)

From \_\_\_\_\_ To \_\_\_\_\_

\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 in</u>	<u>steel</u>	<u>8 Gauge</u>		

Perforations:  
 Type perforation Air Roller  
 Size perforation 4 cuts per Ft.  
 From 80 feet to 25 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 10-14, 2003  
 Date completed 10-15, 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Very low yield</u>		

9. WATER LEVEL

Static water level 80 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Redding Drilling Contractor  
 Address 3955 Blue Diamond Rd #4 Contractor  
Las Vegas, NV 89139  
 Nevada contractor's license number issued by the State Contractor's Board 38155  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1417  
 Signed Floyd Mitchell  
 By driller performing actual drilling on site or contractor  
 Date 10-16-03