

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 91039
 Permit No. _____
 Basin 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48954

1. OWNER TERRY GESS ADDRESS AT WELL LOCATION 17 Terrell, Wellington, NV 89
 MAILING ADDRESS 377 E. PINE BISHOP CA, 93514
 2. LOCATION NW 1/4 SE 1/4 Sec. 33 T 12 N/S R 23 E LYON County
 PERMIT NO. 9-003-03 Parcel No. PINE NUT RANCH ESTATES Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY TOPSOIL/LAM	-	0	6	6
D.G. ALLUVIAL/BOULDERS	-	6	48	42
ALLUVIAL DG. MIXED ROCK	-	48	105	57
SANDY BWN CLAY/ROCK		105	185	80
COARSE SAND/GRAVEL		185	210	25
SOLID HARD FORMATION		210	230	20
COARSE SAND/GRAVEL		230	250	20

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 60 Feet
6 5/8 Inches 60 Feet 250 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>12.92</u>	<u>.188</u>	<u>+1.5</u>	<u>250</u>

Perforations:
 Type perforation FACTORY SAW SLOT
 Size perforation .060 X 3" X 8" OC X 6 ROWS
 From 190 feet to 250 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 160 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature 51 °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Drilling Contractor
 Address P.O. Box 92 Smith/Ber 89430 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 32166A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
 Signed Edmund Miller
 by driller performing actual drilling on site or contractor
 Date Oct 29-03

Date started 10-12-03, 19_____
 Date completed 10-29-03, 19_____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input checked="" type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>BALE</u>	<u>12</u>	<u>10</u>	<u>12</u>
<u>pump</u>	<u>20</u>	<u>13</u>	<u>2 hrs</u>

RECEIVED
 10-30-03 11:37 AM
 STATE ENGINEERS OFFICE