WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91051
Permit No.
Basin 087

NOTICE OF INTENT NO. 49171

1. OWNER Truckee Meadows Water Reclamation
MAILING ADDRESS 8500 Clean Water Way
Reno, NV 89502

ADDRESS AT WELL LOCATION 8500 Clean Water Way
Reno,Nevada 89502

2. LOCATION NW 1/4 NE 1/4 Sec. 15 T 19N N/S R 20E E Washoe County
PERMIT NO. 46467 Issued by Water Resources
021-020-02 Parcel No.
Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Bail out well from 72 feet to 100 feet,No added perforation needed per phone conversation with Tom Gallagher state water resource.Install trimie pipe to 100 feet and pump approx 11000 lbs of neat cement to the surface of casing,remove trimie pipe. Total Depth 100 feet				

Date started 10/31/2003 , 19__
Date completed 11/07/2003 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10	24.0	12 gauge	-3	100

Perforations:
Type perforation Mills knife
Size perforation 3/16 x 1-1/2
From 53 feet to 67 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 per well log
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 17 feet feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service (Contractor)
Address P.O. Box 60130 (Contractor)
Reno,Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 35387-B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
Signed Larry Welch (By driller performing actual drilling on-site or contractor)
Date 11/07/2003

USE ADDITIONAL SHEETS IF NECESSARY