

- COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 91084
 Permit No. _____
 Basin 107

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.300

NOTICE OF INTENT NO. **49699**

1. OWNER **ROB STINETTE CONSTRUCTION**
 MAILING ADDRESS **P.O. BOX 11**
WELLINGTON, NV 89444
 ADDRESS AT WELL LOCATION **29 GRAND VIEW**
SMITH VALLEY, NV 89444

2. LOCATION **SE 1/4 SE 1/4 Sec 11 T 11 N R 23 E** **LYON** County
 PERMIT NO. **Sw 9-072-04**

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BLOW SANDS		0	3	3
HARDPAN CLAY		3	6	3
SOFT SILTY SANDS		6	25	19
COURSE DG SANDS		25	65	40
BROWN CLAY		65	93	28
DG SANDS AND SMALL GRAVELS	XX	93	120	27

8. WELL CONSTRUCTION

Depth Drilled **120** Feet Depth Cased **120** Feet
 HOLE DIAMETER (BIT SIZE)
 From **10 5/8** Inches To **0** Feet **120** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	120

Perforations:
 Type perforation **MILL SLOT**
 Size perforation **3X 3/32**
 From **100** feet to **120** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **50** feet to **120** feet

9. WATER LEVEL
 Static water level **60** feet below land surface
 Artesian flow _____ G.P.M. **20+** P.S.I.
 Water temperature **COLD** °F Quality **GOOD**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **CAPITAL CITY WELL DRILLING AND PUMPS**
 (CONTRACTOR)
 Address **20 KIT KAT DRIVE**
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board **0055548** *41775 WF*
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2157**
 Signed *Rich Crane*
 By driller performing actual drilling on site or contractor
 Date **9/15/03**

Date started **911, 20 03**
 Date completed **9/12, 20 03**

7. WELL TEST DATE

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	25	3 HRS