WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91085
Permit No.
Basin 102

NOTICE OF INTENT NO. 16980

1. OWNER Tenaya-Lumas Investment Co.
MAILING ADDRESS Verdi, NV, Box 279
Verdi NV 89439
ADDRESS AT WELL LOCATION 2795 Ramsey Cut-Off Silver Springs NV 89429

2. LOCATION ~~SW~~ ¼ SW ¼ Sec. ~~35~~ 35 T. 18 (N) S R. 24 (E) Lyon County
PERMIT NO. NW NA (Issued by Water Resources) 15-211-~~22~~ 21 (Parcel No.) Tenaya-Lumas Lot # 3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt & Broken Shale.		0	5	5'
Black Shale.		5	70'	65'
Brown & Orange Shale.		70	115	45'
Tan Colored Shale.		115	138	18'
Gray Colored Shale (Hard)		138	190	52'
Green Colored Shale.		190	230	40'
Black Hard Shale		230	245	15'
Broken Hard Shale, Small Amt. water	✓	245	260	15'
Black Hard Loose Shale with quartz	Fault AT 260' ✓	260	270	10'

Date started 3/23, 1991
Date completed 3/27 Moved Off, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100+	250'	3 Hrs.

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 270' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11" Inches	0 Feet	60' Feet
8 3/4 Inches	60 Feet	275' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	+1	270

Perforations:
Type perforation Torch, Cut
Size perforation
From 250' feet to 270' feet
From feet to feet
From 5# Rows feet to 100 Preforations
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60' feet to 270' feet

9. WATER LEVEL
Static water level 179' 6" feet below land surface
Artesian flow NA G.P.M. P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc. (Contractor)
Address P.O. Box 599 (Contractor)
Silver Springs Nv. 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Nathina L. Leach (By driller performing actual drilling on site or contractor)
Date 3/30/91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627