


COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 91110
 Permit No. _____
 Basin 105
 NOTICE OF INTENT NO. 49707



PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER GARY PETERSON
 MAILING ADDRESS P.O. BOX 2126
GARDNERVILLE, NV 89410
 ADDRESS AT WELL LOCATION 1543 SANCHEZ DR
GARDNERVILLE, NV 89410

2. LOCATION NW 1/4 NW 1/4 Sec 35 T 13 N R 20 E DOUGLAS County
 PERMIT NO. 1320-35-001-050

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
COBBLES AND CEMENTED GRAVELS		0	9	9
COURSE GRAVELS		9	26	17
BROWN CLAY		26	34	8
OBSIDIAN GRAVELS		34	126	92
BROWN CLAY		126	159	33
SMALL DG SANDS		159	187	28
BROWN GUMMY CLAY		187	206	17
COURSE FRACTURED GRAVELS	XXX	206	240	34

8. WELL CONSTRUCTION

Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 3/4</u> Inches	<u>0</u> Feet	<u>240</u> Feet
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>240</u>

Perforations:
 Type perforation FACTORY MILL SLOT
 Size perforation 3 X 3/32
 From 220 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 240 feet

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. 30+ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name CAPITAL CITY WELL DRILLING
 (CONTRACTOR)

Address 20 KIT KAT DRIVE
 (CONTRACTOR)
CARSON CITY NV, 89706
 Nevada contractor's license number issued by the State Contractor's Board 0055548
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
 Signed Kirk Crane
 By driller performing actual drilling on site or contractor
 Date 10/22/03

Date started 10/18, 20 03
 Date completed 10/21, 20 03

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
	Draw Down (Feet Below Static)		
G.P.M.	Time (Hours)		
<u>30+</u>	<u>45</u>	<u>3 HRS</u>	

PREPARED
 OCT 28 AM 054
 STATE ENGINEERS OFFICE