

OFFICE USE ONLY  
 Log No. 9111  
 Permit No. \_\_\_\_\_  
 Basin. 092A  
 NOTICE OF INTENT NO. 39904

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Rob Henderson ADDRESS AT WELL LOCATION 10215 WHITE OWL  
 MAILING ADDRESS 10215 WHITE OWL RENO, NV 89506  
 2. LOCATION NE 1/4 SE 1/4 Sec. 13 T. 21 S. R. 18 E. WASHOE County  
 PERMIT NO. N/A 086-250-45  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>LT. BROWN CLAY</u>		<u>211</u>	<u>215</u>	
<u>BROWN SAND</u>		<u>215</u>	<u>218</u>	
<u>BROWN CLAY</u>		<u>218</u>	<u>221</u>	
<u>SAND</u>		<u>221</u>	<u>234</u>	
<u>BROWN CLAY W/ SAND STRINGERS</u>		<u>234</u>	<u>295</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 295 Feet Depth Cased 295 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 1/8 Inches To 180 Feet 295 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5.563</u>	<u>2.86</u>	<u>.265 PVC</u>	<u>-1</u>	<u>295</u>

Perforations:  
 Type perforation MILL SLOT  
 Size perforation .030"  
 From 175 feet to 295 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal N/A  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 8-12-03, 19\_\_\_\_  
 Date completed 8-26-03, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>APPROX 50</u>	<u>2.90</u>	<u>6 hrs</u>

9. WATER LEVEL  
 Static water level 170' feet below land surface  
 Artesian flow none G.P.M. none P.S.I.  
 Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name MILLER & SONS DRILLING Contractor  
 Address P.O. Box 8056 Contractor  
RENO, NV 89507  
 Nevada contractor's license number 37915  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1418  
 Division of Water Resources, the on-site driller:  
 Signed Bruce Miller  
 By driller performing actual drilling on site or contractor  
 Date 9-21-03

RECEIVED  
 NOV-3 PM 1:21  
 STATE ENGINEERS OFFICE