

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 91119
 Permit No. 69428 T
 Basin 061



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51520

1. OWNER Barrick Goldstrike Mines BW-39 ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803

2. LOCATION SE 1/4 SW 1/4 Sec. 13 T 36N N/S R 49 E Eureka County
 PERMIT NO. 69428-T Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Multicolored rock		0	40	40
Black rock, some gray clay		40	190	150
Fractured black rock, traces of black clay		190	890	700
Gray and black rock		890	980	90
Black rock, some gray rocks and fractures		980	1330	350
Black and gray rock, some white rock		1330	1490	160
Black and gray rock		1490	1570	80
Black rock, some fractures		1570	1660	90
Gray rock, some fractures		1660	1820	160
Fractured white rock		1820	1830	10
Variable gray and black rock, traces of white		1830	2710	880
Black and gray rock, fractured		2710	2760	50
Black and gray rock		2760	2780	20
Fractured black, gray and some white rock		2780	2790	10
Black and gray rock		2790	2843	53
Black and white rock		2843	2980	137
Black rock, occasional white and gray rock		2980	3040	60
As above, fractured		3040	3050	10
As above, few fractures		3050	3235	185

Continued on next page

Date started 8/13/2003 19
 Date completed 10/26/2003 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M. <u>280</u>	<u>0</u>	<u>1</u>
<u>80:1 Hd 3 - ADN CO</u>		
<u>STATE ENGINEERS OFFICE</u>		

8. WELL CONSTRUCTION

Depth Drilled 2843 Feet Depth Cased 3235 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>46</u>	<u>0</u>	<u>60</u>	<u>60</u>
<u>31</u>	<u>60</u>	<u>2843</u>	<u>2843</u>
<u>22</u>	<u>2836</u>	<u>3235</u>	<u>3235</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>40</u>	<u>210.93</u>	<u>0.5000</u>	<u>0</u>	<u>60</u>
<u>24</u>	<u>110.09</u>	<u>0.4375</u>	<u>Blank</u>	<u>Section</u>
<u>24</u>	<u>94.62</u>	<u>0.3750</u>	<u>Louver</u>	<u>Section</u>

Perforations:

Type perforation Louver
 Size perforation 0.125"

From	To	Feet
<u>591.44</u>	<u>631.54</u>	<u>60</u>
<u>792.12</u>	<u>832.23</u>	<u>60</u>
<u>1196.13</u>	<u>1233.27</u>	<u>60</u>
<u>1593.91</u>	<u>1634.01</u>	<u>60</u>
<u>1834.33</u>	<u>1914.68</u>	<u>60</u>

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 198' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 198 feet to 2828.2 feet

9. WATER LEVEL
 Static water level 1730 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature 118 °F Quality Fair

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2144
 Signed Paul Stoddard
 By driller performing actual drilling on-site or contractor
 Date 10/29/03

BSTL