WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91121
Permit No.
Basin 101

NOTICE OF INTENT NO. 48968

1. OWNER CRAIG JACKSON
MAILING ADDRESS 380 SHECKLER CUTOFF
FALLON, NV 89406

ADDRESS AT WELL LOCATION SHECKLER CUTOFF

2. LOCATION SW 1/4 SW 1/4 Sec. 32 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources
Parcel No. 008 573 14
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
BROWN SAND		1	18	17
BROWN CLAY		18	20	2
BROWN SAND		20	38	18
BROWN CLAY		38	40	2
GREY SAND		40	50	10
GREY CLAY		50	55	5
GREY SAND		55	75	20
GREY CLAY		75	78	3
BROWN SAND		78	90	12

RECEIVED
03 AUG 11 PM 12:50
STATE ENGINEER'S OFFICE

Date started 6/19/~~1903~~ 2003 , 19__
Date completed 7/25/~~1903~~ , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 HR

8. WELL CONSTRUCTION
Depth Drilled 90 Feet Depth Cased 90 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 5/8	Inches	50	Feet	90	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	90

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 83 feet to 88 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 16' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed By driller performing actual drilling on-site or contractor
Date 8/6/~~1903~~ 2003

USE ADDITIONAL SHEETS IF NECESSARY