

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 91135  
 Permit No. \_\_\_\_\_  
 Basin V62  
 NOTICE OF INTENT NO. 25497

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Baker ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1200 E. Casey 1200 E. Casey  
Pahrump, NV 89060  
 2. LOCATION NW 1/4 NE 1/4 Sec. 11 T 21S N/S R 53E E Nye County  
 PERMIT NO. 44-441-15 Calneva Acres  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>brown loam</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>grey loam</u>		<u>8</u>	<u>12</u>	<u>4</u>
<u>brown loam</u>	<u>x</u>	<u>12</u>	<u>74</u>	<u>62</u>
<u>brown caleche</u>	<u>x</u>	<u>74</u>	<u>76</u>	<u>2</u>
<u>brown loam</u>	<u>x</u>	<u>76</u>	<u>128</u>	<u>52</u>
<u>grey clache</u>	<u>x</u>	<u>128</u>	<u>137</u>	<u>9</u>
<u>brown loam</u>	<u>x</u>	<u>137</u>	<u>147</u>	<u>10</u>
<u>See next line</u>	<u>x</u>	<u>147</u>	<u>160</u>	<u>13</u>
<u>brown loam with caleche strings</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160+1 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
11 Inches 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation sawcut  
 Size perforation .188  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Strickland Construction Co., Inc. Contractor  
 Address 5801 S. Homestead Contractor  
Pahrump, NV 89048  
 Nevada contractor's license number issued by the State Contractor's Board 40277  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086  
 Signed \_\_\_\_\_ By driller performing actual drilling on-site or contractor  
 Date 11.22.03

Date started 11/19/03, 19\_\_\_\_  
 Date completed 11/19/03, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DONR/DWR  
 RECEIVED  
 NOV 26 2003  
 LAS VEGAS OFFICE