WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91141
Permit No.
Basin 162

NOTICE OF INTENT NO. 25489

1. OWNER A. Borasky
MAILING ADDRESS 5121 N. Linda
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
5121 N. Linda

2. LOCATION SW 1/4 SW 1/4 Sec. 16 T 19S N/S R 53E E Nye County
PERMIT NO. (Issued by Water Resources) 29-274-28 (Parcel No.) Country Place (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown silty loam		0	21	21
See next line		21	65	44
brown loam with caleche strings				
See next line		65	80	15
brown clay with caleche strings				
See next line	x	80	115	35
brown loam with gravel strings				
See next line	x	115	200	85
brown loam with caleche strings				

DCNR/DWR
RECEIVED
NOV 26 2003
LAS VEGAS OFFICE

Date started 9/22/03 , 19__
Date completed 9/22/03 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175+1 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	175	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	175

Perforations:
Type perforation sawcut
Size perforation .188
From 160 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 5801 S. Homestead (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Larry Strickland (By driller performing actual drilling on-site or contractor)
Date 10-25-03