WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91142
Permit No.
Basin 162

NOTICE OF INTENT NO. 24988

1. OWNER Juventino Flores
MAILING ADDRESS 2720 W. Blosser
Pahrump, NV 89060

ADDRESS AT WELL LOCATION
2720 W. Blosser Ranch

2. LOCATION SE 1/4 NW 1/4 Sec. 31 T 19S N/S R 53E E Nye County
PERMIT NO. _____ Issued by Water Resources | 28-222-12 Parcel No. | Bellvista Unit 1 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown loam		0	56	56
grey loam	x	56	65	9
brown loam	x	65	160	95

DCNR/DWR
RECEIVED
NOV 26 2003
LAS VEGAS OFFICE

Date started 11/6/03, 19__
Date completed 11/6/03, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140+1 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	160

Perforations:
Type perforation sawcut
Size perforation .188
From 140 feet to 160 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 5801 S. Homestead (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed _____ (By driller performing actual drilling on site or contractor)
Date 11-20-03