WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91168
Permit No.
Basin 212

NOTICE OF INTENT NO. 79416

1. OWNER Contri Const.
MAILING ADDRESS P.O. Box 87739
Las Vegas, NV 89193

ADDRESS AT WELL LOCATION Magic Way - Las Vegas Wash

2. LOCATION NE ¼ NE ¼ Sec. 28 T. 21 N/S R. 63 E. Clark County
PERMIT NO. 160-28-510-006 (Issued by Water Resources) DW-NC6 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE Temp Dewater
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

WELL TYPE
☐ Cable ☐ Rotary ☐ PVC
☐ Air ☐ Other Ducket Rose

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Well #1 Sandy Clay | | 0 | 9 | |
| Sands + Gravel | | 9' | 14' | |
| Silty Clays | | 14' | 21' | |
| Silty Sands | | 21' | 25' | |
| Well #2-5 | | | | |
| Same as #1 | | | | |

DCNR/DWR
RECEIVED
SEP 19 2003
LAS VEGAS OFFICE

Date started 9-15-03, 19
Date completed 9-15-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 25' Feet Depth Cased 25' Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 24" | 0 | 25' |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | PVC | Sec-40 | 0 | 5' |
| | | | | |
| | | | | |

Perforations:
Type perforation Saw Cut
Size perforation .032
From 5 feet to 25' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 25' feet

9. WATER LEVEL
Static water level 6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering Contractor
Address 536 E Maitland St. Contractor
Ontario CA 91761
Nevada contractor's license number issued by the State Contractor's Board 0031246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1985
Signed By driller performing actual drilling on site or contractor
Date 9-15-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627