WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91166
Permit No.
Basin 212

NOTICE OF INTENT NO. 49416

1. OWNER Contri Const.
MAILING ADDRESS P.O. Box 97739
Las Vegas, NV 89193

ADDRESS AT WELL LOCATION Magic Way - Las Vegas Wash

2. LOCATION NE ¼ NE ¼ Sec. 28 T. 21 N S R. 63 E. Clark County
PERMIT NO. DW-1166 (Issued by Water Resources) 160-28-510-006 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE Trump Dewatering
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Bucket Auger

6. LITHOLOGIC LOG

	Material	Water Strata	From	To	Thickness
Well #1	Sand, Clay		0	10	
	Silty Sand		10	20	
	Stiff Silty Sand		20	27	
	Sands + Gravels		27	37	
	Silty Sands and Gravel		37	39	
	Clay with Cobbles		39	40	
Well #2	Same as #1				
Well #3	Same as #1				
Well #4	Same as #1				
Well #5	Sand Clay		0	8	
	Silty Sand + Gravel		8	21	
	Stiff Silty Sand		21	29	
	Sands + Gravels		29	33	
	Silty Sand with Clay Lenses		33	38	
	Hard Clay		38	40	
Well #6	Same as #5				

Date started 9-2-03, 19
Date completed 9-2-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR
RECEIVED
SEP 19 2003
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40' Feet

HOLE DIAMETER (BIT SIZE)
24" Inches From 0 Feet To 40' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8'	PVC	Sch-40	0	20'

Perforations:
Type perforation Saw Cut
Size perforation .032
From 20 feet to 40' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 40' feet

9. WATER LEVEL
Static water level 7 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering (Contractor)
Address 536 E. Maitland St. (Contractor)
Ontario CA 91761
Nevada contractor's license number issued by the State Contractor's Board 0031246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1985
Signed [signature] By driller performing actual drilling on site or contractor
Date 9-2-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627