

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 91168
Permit No. _____
Basin 212
NOTICE OF INTENT No. 47416

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Conti Const. ADDRESS AT WELL LOCATION Magie Way - Las Vegas Wash
MAILING ADDRESS P.O. Box 97739
Las Vegas, NV 89153
2. LOCATION NE 1/4 NE 1/4 Sec. 28 T 21 N R 63 E Clark County
PERMIT NO. DW-1166 Issued by Water Resources Parcel No. 160-28-510-006 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE Dewatering WELL TYPE
 Domestic Irrigation Test Cable Rotary PVC
 Municipal/Industrial Monitor Stock Air Other Bueller Aye

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Clay</u>		<u>0</u>	<u>10</u>	
<u>Silty Sand</u>		<u>10</u>	<u>20</u>	
<u>Silt. Silty Sand</u>		<u>20</u>	<u>27</u>	
<u>Sands + Gravels</u>		<u>27</u>	<u>37</u>	
<u>Silty Sands w/ gravel</u>		<u>37</u>	<u>39</u>	
<u>Clay with cobbles</u>		<u>39</u>	<u>40</u>	
<u>Same as #1</u>				
<u>Same as #1</u>				
<u>Same as #1</u>				
<u>Sand Clay</u>		<u>0</u>	<u>8</u>	
<u>Silty Sand + Gravel</u>		<u>8</u>	<u>21</u>	
<u>Silt. Silty Sand</u>		<u>21</u>	<u>29</u>	
<u>Sands + Gravels</u>		<u>29</u>	<u>33</u>	
<u>Silty Sand with Clay lenses</u>		<u>33</u>	<u>38</u>	
<u>Hard Clay</u>		<u>38</u>	<u>40</u>	
<u>Same as #5</u>				

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet
HOLE DIAMETER (BIT SIZE)
From 0 Feet To 40 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>	<u>PVC</u>	<u>3/4"</u>	<u>0</u>	<u>20'</u>

Perforations:
Type perforation Saw Cut
Size perforation 1.032
From 20 feet to 40' feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal _____ Neat Cement
Placement Method: Pumped Concrete Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 0 feet to 40' feet

9. WATER LEVEL
Static water level 7 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Coal °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Groffin Dewatering Contractor
Address 536 E. Main St. Ontario CA 91761 Contractor
Nevada contractor's license number issued by the State Contractor's Board. 0031246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller. M-1985
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 9-2-03

Date started 9-2-03, 19____
Date completed 9-2-03, 19____

7. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift
G.P.M. _____ Draw Down (Feet Below Static) DCNR/DWR Time (Hours) _____
RECEIVED
SEP 19 2003
LAS VEGAS OFFICE