

OFFICE USE ONLY
 Log No. 91781
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22650

1. OWNER Partr. Court. ADDRESS AT WELL LOCATION Vegas Valley + Hollywood
 MAILING ADDRESS 1720 E. Lake Meade Dr. Henderson, NV
 2. LOCATION NW 1/4 SW 1/4 Sec. 14 T. 21 N. R. 63 E. Clark County
 PERMIT NO. DW-1170 Parcel No. 161-14-399-001 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Tring Dewatering
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Bucket Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silty Clay (Dry)</u>		<u>0</u>	<u>15'</u>	
<u>Silty Sands</u>		<u>15'</u>	<u>22'</u>	
<u>Clay</u>		<u>22'</u>	<u>35'</u>	
<u>Silty Clay (Dry)</u>		<u>0</u>	<u>15'</u>	
<u>Silty Sands</u>		<u>15'</u>	<u>25'</u>	
<u>Clay</u>		<u>25'</u>	<u>35'</u>	
<u>Silty Clay (Dry)</u>		<u>0</u>	<u>17'</u>	
<u>Silty Sands</u>		<u>17'</u>	<u>20'</u>	
<u>Clay</u>		<u>20'</u>	<u>35'</u>	
<u>Same as #3</u>				

8. WELL CONSTRUCTION
 Depth Drilled 37 Feet Depth Cased 37 Feet
 HOLE DIAMETER (BIT SIZE)
 From 24" To 35"
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>DWC</u>	<u>Sec-40</u>	<u>0</u>	<u>15'</u>

 Perforations:
 Type perforation Saw Cut
 Size perforation 1.672
 From 15' feet to 25' feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 37' feet

Date started 9-17-03, 20____
 Date completed 9-17-03, 20____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 13 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Griffin Dewart Contractor
 Address 536 E. Main St. Ontario CA 91761
 Nevada contractor's license number issued by the State Contractor's Board 0031240
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1985
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 9-17-03

DCNR/DWRH
 RECEIVED

OCT 22 2003

LAS VEGAS OFFICE

