

OFFICE USE ONLY
 Log No. 9183
 Permit No. _____
 Basin 212
 NOTICE OF INTENT NO. 22650

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Contri. Conot. ADDRESS AT WELL LOCATION Vegas Valley + Hollywood
 MAILING ADDRESS 1720 E. Lake Meade Dr. Henderson, NV
 2. LOCATION NW 1/4 SW 1/4 Sec. 14 T. 21 N. R. 63 E Clark County
 PERMIT NO. DW-1170 Parcel No. 161-14-779-001 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Temp Domestic
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Bucket Aug

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Silty Clay (Dry)</u>		<u>0</u>	<u>15'</u>	
<u>Silty Sands</u>		<u>15'</u>	<u>22'</u>	
<u>Clay</u>		<u>22'</u>	<u>35'</u>	
<u>Silty Clay (Dry)</u>		<u>0</u>	<u>15'</u>	
<u>Silty Sands</u>		<u>15'</u>	<u>25'</u>	
<u>Clay</u>		<u>25'</u>	<u>35'</u>	
<u>Silty Clay (Dry)</u>		<u>0</u>	<u>17'</u>	
<u>Silty Sands</u>		<u>17'</u>	<u>26'</u>	
<u>Clay</u>		<u>26'</u>	<u>35'</u>	
<u>Same as #3</u>				

DONR/DWR
RECEIVED
OCT 20 2003
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 32 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 24" To 35"
 Inches Feet
 _____ Feet _____ Feet
 _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>DWC</u>	<u>Sec-410</u>	<u>0</u>	<u>15'</u>

Perforations:
 Type perforation Saw Cut
 Size perforation 1 1/2"
 From 15' feet to 25' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 30 feet

9. WATER LEVEL
 Static water level 13 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the reports are true to the best of my knowledge.
 Name Griffin Dowd Contractor
 Address 526 E. Mitchell St. Ontario CA 91761 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0031240
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1985
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 9-17-03

Date started 9-17-03, 20.....
 Date completed 9-17-03, 20.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			