

9-10-03 9:18 07  
 OFFICE USE ONLY  
 Log No. 91008  
 Permit No. 212  
 Basin 212  
 25286

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25286  
4150 S HOLLYWOOD BLVD

1. OWNER CLARK COUNTY SANITATION DISTRICT ADDRESS AT WELL LOCATION LAS VEGAS, NV  
 MAILING ADDRESS 3877 E. FLAMINGO RD.  
LAS VEGAS, NV 89122

2. LOCATION NW 1/4 NW 1/4 Sec. 23 T. 21 N/S R. 62 E. CLARK County  
 PERMIT NO. DW-1169 Parcel No. 161-23-101-001 Subdivision Name Tradewest Construction  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other DEWATER

4. PROPOSED USE water  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>14-Dewater wells</u>				
<u>Sandy Clay</u>		<u>0</u>	<u>8'</u>	<u>8'</u>
<u>Silt</u>	<u>x</u>	<u>8'</u>	<u>12'</u>	<u>4'</u>
<u>Silt/Gray clay</u>	<u>xx</u>	<u>12'</u>	<u>30'</u>	<u>23'</u>

DCNR/DWR  
 RECEIVED  
 OCT 20 2003  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
24 Inches 0 Feet 30 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	<u>36.71</u>	<u>0.250</u>	<u>0</u>	<u>30</u>

Perforations: Machine  
 Type perforation 1/4 x 2 1/2x  
 Size perforation 0 feet to 30 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 0 feet to 10' 30 feet

9. WATER LEVEL  
 Static water level 18' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 9/29/03, 20 \_\_\_\_\_  
 Date completed 10/3/03, 20 \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING INC. Contractor  
 Address 4847 West Tompkins Ave. Contractor  
LAS VEGAS, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 18917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301

Signed Paul S. Allen Jr.  
 By driller performing actual drilling on site or contractor  
 Date 10/16/03