WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91262
Permit No. 63513
Basin 212

NOTICE OF INTENT NO. 25544

1. OWNER Kimball Hill Homes
MAILING ADDRESS
ADDRESS AT WELL LOCATION 7985 Racel Ave, LV. NV 89131

2. LOCATION SW ¼ SE ¼ Sec. 9 T. 19 S N/S R. 60 E. Clark County
PERMIT NO. 63513 Issued by Water Resources | 125-09-801-001 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
A. Depth of Well - 310 FT				
B. The depth to which the materials used to plug the well were placed: 310 FT				
C. The type, size and location of the perforations which were made in the casing Type: Knife Size: approx. 3/16 x 2" Location: Bottom up to 75 FT 4 perforations per foot 4 times around.				
D. No Debris Present				
E. The materials used to plug the well: 27 sack neat cement.				
Sec. 9. Neat Cement by Tremie pipe.				

DCNR/DWR
RECEIVED
DEC 03 2003
LAS VEGAS OFFICE

Date started 11-20-03, 20
Date completed 11-20-03, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 128 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick
Contractor
Address 5360 N. Bonita Vista St.
Contractor
Las Vegas, Nev. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick
By driller performing actual drilling on site or contractor
Date 11-21-03

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627