

2 wells

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 91264
Permit No. 212
Basin 17

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 253916

1. OWNER BOB HARRIS
MAILING ADDRESS 6115 S. PEACOCK RD. LAS VEGAS NV
ADDRESS AT WELL LOCATION 6115 S PEACOCK, LAS VEGAS, NV
2. LOCATION NE 1/4 SE 1/4 Sec. 36 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. 162-36-702-013
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>TYPE II FILL</u>		<u>0.0</u>	<u>2.0</u>	<u>2.0</u>
<u>CLAY w COBBLES</u>		<u>2.0</u>	<u>12.0</u>	<u>10.0</u>
<u>CLAY w SILT</u>		<u>12.0</u>	<u>16.0</u>	<u>4.0</u>
<u>CLAY w GRIT</u>		<u>16.0</u>	<u>25.0</u>	<u>9.0</u>

8. WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased _____ Feet
HOLE DIAMETER (BIT SIZE)
From _____ To _____
11 1/2 Inches 0 Feet 25 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.250</u>		<u>SCH 40 PVL</u>	<u>0.0</u>	<u>25.0</u>

Perforations:
Type perforation MACHINE SLOTTED
Size perforation .020
From 25.0 feet to 5.0 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 1' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 25 feet to 3 feet

9. WATER LEVEL
Static water level 14.0 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 10-1, 2003
Date completed 10-1, 2003

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

Name EAGLE DRILLING Contractor
Address 7150 PLACID ST. LAS VEGAS, NV 89119 Contractor
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 12-8-03