

3 wells.

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 912 (PS)

Permit No. 212

Basin 212

NOTICE OF INTENT NO. 25626

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Raymond G. Voss ADDRESS AT WELL LOCATION 333 E CHARLESTON BLVD. LAS VEGAS NV

MAILING ADDRESS 4 Cambridge Dr. LA, Palms, CA

2. LOCATION Sec 34 1/4 SW 1/4 Sec. 34 T 20 N/S R 01 E CLARK County

PERMIT NO. 139-31-410-137 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC Air Other ITSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TYPE II FILL		00	2.5	2.5
clay w/ SAND		2.5	8.0	5.5
clay w/ silt		8.0	12.5	4.5
clay w/ SAND		12.5	20.0	7.5
clay + SAND w/ GRAVEL		20.0	25.0	5.0

DCNR/DWR RECEIVED
DEC 17 2003
LAS VEGAS OFFICE

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

1 1/2 Inches From 0 Feet To 25 Feet

_____ Inches _____ Feet _____ Feet

_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.250</u>		<u>sch 40 PVC</u>	<u>00</u>	<u>25.0</u>

Perforations:
 Type perforation MAJOR SLOTTED
 Size perforation 1020

From 25.0 feet to 50 feet

From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout

Depth of Seal 1

Placement Method: Pumped Poured

Gravel Packed: Yes No

From 25 feet to 3 feet

Date started 9/29, 2003
 Date completed 9/29, 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level 13' feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EAGLE DRILLING Contractor

Address 7150 PLACID ST. LAS VEGAS, NV 89119 Contractor

Nevada contractor's license number issued by the State Contractor's Board 51266

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202

Signed [Signature] By (driller performing actual drilling on site or contractor)

Date 12/8/03