

OFFICE USE ONLY
 Log No. 91290
 Permit No. 67589
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49138

1. OWNER DAVID M. SEMAS ADDRESS AT WELL LOCATION 317 Buffalo Creek RD
 MAILING ADDRESS 2241 PARK PLACE
MINOEN NV 89413 GARONVILLE NV 89410
 2. LOCATION N 1/4 SW 1/4 Sec. 15 T 12 S R 19 E Douglas County
 PERMIT NO. 67589-67588 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SOIL, Decomposed Granite, COBBLES + Boulders		0	60	60
DG soft to firm		60	160	100
DG w/clay		160	220	60
DG Broken w/FRACTURES	X	220	440	220

8. WELL CONSTRUCTION
 Depth Drilled 440 Feet Depth Cased 440 Feet
 HOLE DIAMETER (BIT SIZE)
 From 15" Inches To 440 Feet
 From 0 Feet To 440 Feet
 From 0 Feet To 440 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"		.188	12	240

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 3/32" x 3"
 From 240 feet to 440 feet
 From 240 feet to 440 feet
 From 240 feet to 440 feet
 From 240 feet to 440 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100' feet to 440' feet

9. WATER LEVEL
 Static water level 150' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started 9-10-03, 19____
 Date completed 10-10-03, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Air</u>	<u>60+</u>		<u>15</u>
<u>pump</u>	<u>73+-</u>	<u>146'</u>	<u>8</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Nevada Drilling + Pump LLC
 Address 3540 GREEN ACRES DR
CARSON CITY NV 89705
 Nevada contractor's license number issued by the State Contractor's Board 52078
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 19020
 Signed John L. Leach
 driller performing actual drilling on site or contractor
 Date 11-10-03

RECEIVED
 03 DEC - PM 11:11
 STATE ENGINEERS OFFICE