REPORT NO. A03.116

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

LOG NO. 91309
PERMIT NO.
BASIN

NOTICE OF INTENT NO. 51463

1. OWNER Robert & Pamela Watson
MAILING ADDRESS 500 Iron Wood Rd. Palomino Valley, NV 89431
ADDRESS OF WELL 500 Iron Wood Road
Palomino Valley, NV 89431

2. WELL LOCATION NE 1/4 NE 1/4 SEC. 20 T 22 R 21 E Washoe COUNTY
PERMIT NO PARCEL NO 76-220-22 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

| MATERIAL | STRATA | FROM | TO | THICKNESS |
|---|---|---|---|---|
| | | | | |
| Salt & Pepper Granite & White, | | 517 | | |
| Lt. Green Granite W/ Black Specs | | 517 | 615 | 98 |
| Mostly Black Granite | | 615 | | |
| With Some White Specs | | 615 | 660 | 45 |
| Salt & Pepper Granite | | 660 | | |
| In and Out of Fractured Granite | | 660 | 796 | 136 |

RECEIVED 03 DEC -2 AM 11:24 STATE ENGINEER'S OFFICE

Notes : Refer to original well log for sanitary seal. The original well log for this well started 5" liner from 325' to 505'. No liner was found. This well has 3 tri cones at 796'.

Date Started 11-14-03 Date Completed 11-20-03

7. WELL TEST DATA

TEST METHOD [ ] Bailer [X] Pump [X] Air Develop

| | GPM | DRAWDOWN | TIME (HRS) |
|---|---|---|---|
| Air | 14 | | 2hrs. |
| Pump | 16 | 126 | 1hr. |
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 796 Depth Cased 796

HOLE DIAMETER (BIT SIZE)
6 Inches 517 Feet 796 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

| Size OD | Weight/Ft | Wall Thickness | From | To |
|---|---|---|---|---|
| 5 | 9.69 | .188 | 256 | 796 |
| | | | | |
| | | | | |
| | | | | |

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 X 3
From 756 Feet to 796 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth
PLACEMENT METHOD: [ ] Pumped [ ] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout [ ] Bentonite
GRAVEL PACKED: [ ] Yes [ ] No
From Feet to Feet

9. WATER LEVEL
Static Water Level 176 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2189
Signed Rosenthal
By driller performing actual drilling on site or contractor
Dated November 20, 2003