COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91313
Permit No.
Basin 105
NOTICE OF INTENT NO. 49709

1. OWNER KURT JOHNSON DEVELOPMENT
MAILING ADDRESS P.O. BOX 1848
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 657 MUSTANG DR
GARDNERVILLE, NV 89410

2. LOCATION SE ¼ SE ¼ Sec 24 T 12 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) 1220-24-701-027 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARD PAN CLAY		0	5	5
BROWN CLAY		5	15	10
COURSE GRAVELS		15	78	63
BROWN CLAY	(DRY)	78	162	84
BROWN GUMMY CLAY		162	192	30
SMALL SILTY SANDS		192	213	21
SMSALL OBSIDIAN SANDS AND GRAVELS	XX	213	250	37

RECEIVED 03 DEC -3 AM 11:12 STATE ENGINEERS OFFICE

Date started 10/26, 20 03
Date completed 10/28, 20 03

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	40	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	250 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	250

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 230 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 250 feet

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M, 30 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAY DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 11/14/03

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429