WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 91333
Permit No.
Basin 212

PRINT OR TYPE ONLY MW-11

NOTICE OF INTENT NO. 22037

1. OWNER Becker Enterprises
MAILING ADDRESS 50 South Jones Blvd., Suite 100, Las Vegas, NV 89107
ADDRESS AT WELL LOCATION 740 South Decatur Blvd., Las Vegas, NV 89107

2. LOCATION NE ¼ SE ¼ Sec. 36 T. 20 N/S R. 60 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 138-36-701-022 Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Monitor ~~Industrial~~ ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphault		0	0.5	0.5
(Fill) Silty sand w/gravel		0.5	7.0	6.5
Clay with gravel		7.0	9.0	2.0
Sandy lean clay		9.0	12.0	3.0
Partially cemented sand & gravel		12	14	2.0
Lean clay with sand	✓	14	20	6.0
Sandy lean clay with gravel	✓	20	34.5	14.5

Date started September 5, 2003
Date completed September 5, 2003

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 2 inches Total depth 29.5 feet
inches
inches
Casing record
Weight per foot 0.7 lbs Thickness 0.154"

Diameter (OD)	From	To
2.375 inches	29.5 feet	0 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete Grout
Depth of seal 10 inches feet
Gravel packed: Yes ☒ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Factory Slot Sch 40 PVC
Size perforation 0.02 inches
From 29.0 feet to 9 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 13.4 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name D. Wilson - Converse Consultants (Contractor)
Address 731 Pilot Rd., Ste H, Las Vegas 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed [signature] (By driller performing actual drilling on site or contractor)
Date OCTOBER 22, 2003

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627