WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91342
Permit No.
Basin 212

NOTICE OF INTENT NO. 24914

1. OWNER Maryland Square Shopping Center
MAILING ADDRESS 777 N. Rainbow Blvd Lasvegas, NV 89107
ADDRESS AT WELL LOCATION 3528 S. Maryland PRWY Lasvegas, NV

2. LOCATION SW ¼ NW ¼ Sec. 14 T. 21 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 162-14-213-002 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG B-16

Material	Water Strata	From	To	Thickness
Asphault				4"
Sand & gravel		0'	3'	3'
Sandy clay w/gravel		3'	14'	
Clay sand		14'	18'	
caliche		18'	19'	
	21'			
Sandy lean clay		19'	30'	

DCNR/LWR
RECEIVED
DEC 03 2003
LAS VEGAS OFFICE

Date started NOV 11, 2003
Date completed NOV 11, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	Sch 40	0'	30'

Perforations:
Type perforation Factory slot
Size perforation .020
From 15' feet to 30' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 12' to surface
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 12' feet to 30' feet

9. WATER LEVEL
Static water level 21' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc. (Contractor)
Address 5115 S. Industrial Rd #104 (Contractor)
Lasvegas, NV 89118
Nevada contractor's license number issued by the State Contractor's Board 0054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed (By driller performing actual drilling on site or contractor)
Date Dec 1 2003

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627