WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91345
Permit No.
Basin 212

NOTICE OF INTENT NO. 22650

1. OWNER Contr. Const.
MAILING ADDRESS 1720 E. Lake Mead Dr.
Henderson, NV

ADDRESS AT WELL LOCATION Vegas Valley & Hollywood

2. LOCATION NW ¼ SW ¼ Sec. 14 T. 21 N R. 62 E Clark County
PERMIT NO. DW-1170 (Issued by Water Resources) 161-14-399-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE Temp Dewatering
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Bucket Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
well #1				
Silty Clay (Dry)		0	14'	
Silty Sands		14'	19'	
Silty Clay		19'	35'	
well #2				
Silty Clay (Dry)		0	13'	
Silty Sands with Gravel		13'	25'	
Silty Sands		25'	30'	
Clay		30'	35'	
well 3				
Silty Clay (Dry)		0	13'	
Silty Sands with Gravel		13'	22'	
Silty Sands		22	25'	
Clay		25	35'	

DCNR/DWR
RECEIVED
OCT 22 2003
LAS VEGAS OFFICE

Date started 9-16-03, 20
Date completed 9-16-03, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35' Feet Depth Cased 35' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
24"	0	35'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	PVC	Sch-40	0	15'

Perforations:
Type perforation Saw Cut
Size perforation .032
From 15' feet to 35' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 35' feet

9. WATER LEVEL
Static water level 13' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering (Contractor)
Address 536 E. Maitland St. (Contractor)
Ontario CA 91761
Nevada contractor's license number issued by the State Contractor's Board 0031246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1985
Signed (By driller performing actual drilling on site or contractor)
Date 9-16-03

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 12-01) (O)-627