

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 22650

1. OWNER Contra Const. ADDRESS AT WELL LOCATION Regas Valley + Hollywood
MAILING ADDRESS 1720 E. Lake Mead Dr. Henderson, NV
2. LOCATION NW 1/4 SW 1/4 Sec. 14 T 21 N 62 E County _____
PERMIT NO. 0W 1170 Issued by Water Resources Parcel No. 161-14-399-001 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE Temp Dewatering
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Budget Bjt

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>11# Dry Clays + Silts</u>		<u>0</u>	<u>15</u>	
<u>Silty Sands</u>		<u>12</u>	<u>18</u>	
<u>Silty Clays</u>		<u>18</u>	<u>25</u>	
<u>Clay</u>		<u>25</u>	<u>35</u>	
<u>2# - Same as #1</u>				
<u>3# - Same as #1</u>				
<u>4# - Same as #1</u>				
<u>5# - Same as #1</u>				
<u>6# - Same as #1</u>				
<u>7# - Same as #1</u>				

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet
HOLE DIAMETER (BIT SIZE)
From 24 Inches To 35 Feet
Inches Feet Feet
Inches Feet Feet
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>PVC</u>	<u>Sch-40</u>	<u>0</u>	<u>15</u>

Perforations:
Type perforation Saw cut
Size perforation 0.32
From 15 feet to 35 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
Depth of Seal _____
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 0 feet to 35 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature Cool °F Quality Good

Date started 10-29 2003
Date completed 10-29 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffith Dewatering Contractor
Address 576 E. Maitland St. Ontario, CA 91761 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0031244
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-19-85
Signed [Signature]
By driller performing actual drilling on site or contractor
Date _____