

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21131

1. OWNER CLARK CO. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 500 S. GRAND CENTRAL PKY  
LAS VEGAS, NEVADA 89155  
 2. LOCATION SE 1/4 SE 1/4 Sec. 27 T. 21 N. R. 62 E. CLARK County  
 PERMIT NO. DW 155 Issued by Water Resources Parcel No. 161-27-896-002 Subdivision Name NA

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Municipal  Irrigation  Test  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other BUCKET

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
INTENT TO DRILL 30 WELLS				
ONLY 18 COMPLETED @ THIS TIME				
CLAY w/ GRAVEL LENSES		0	32	32

8. WELL CONSTRUCTION  
 Depth Drilled 32 Feet Depth Cased 32 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 32  
20 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>	<u>14</u>	<u>.250</u>	<u>0</u>	<u>12</u>

Perforations:  
 Type perforation LOUVERED  
 Size perforation 0.40  
 From 12 feet to 32 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 10'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 10 feet to 32 feet

9. WATER LEVEL  
 Static water level 6 feet below land surface  
 Artesian flow N/D G.P.M. \_\_\_\_\_ F.S.I. \_\_\_\_\_  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started FEBRUARY 10, 2003 19\_\_\_\_\_  
 Date completed JULY 10, 2003 19\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ZELLE DEWATERING CONSTRUCTION CO. Contractor  
 Address 5175 CLAY Contractor  
WYOMING, MICH 49548  
 Nevada contractor's license number issued by the State Contractor's Board ABDS 2149  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 50326  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10-3-03